


## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1461

Dated: 29.05.25

It is certified that an inspection team headed by Executive Engineer(Name of Officers with designation) from P.H.E.D.(Name of Department/ Office) inspected the J.K. INTERNATIONAL SCHOOL, NH-28, PAHARPUR, KUCHAIKOTE, GOPALGANJ (BIHAR) - 841501

(Name & Address of the school) on 26.05.2025 (date of inspection) and found that the  
J.K. INTERNATIONAL SCHOOL (Name of school) has safe drinking water  
 facilities for the students and members of staff of the institution and is maintaining the hygienic  
 sanitation condition in the school building & the campus as per norms prescribed by the Central/  
 State/ U.T. Govt.


The above is valid for a period of ONE YEARSignature with Seal: Name : Pandeep Kumar JhaDesignation : Executive Engineer
 Name & Address of the Office / Department :  
Executive Engineer  
P.H. Division, Gopalganj

To

J.K. INTERNATIONAL SCHOOL  
 NH-28, PAHARPUR, KUCHAIKOTE,  
 GOPALGANJ (BIHAR) - 841501

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,  
 translated notarized version in English be uploaded along with the original vernacular certificate  
 as a single pdf.

  
**Principal**  
**J.K. International School**  
**N.H-28, Paharpur, Kuchaikote, Gopalganj**


  
**Principal**  
**J.K. International School**  
**Paharpur, Kuchaikote, Gopalganj**



**Government of Bihar  
Public Health Engineering Department  
Water Quality Test Report**


District Name: Gopalganj

Division Name: P.H.Division Gopalganj


Division Name: P.H.Division Gopalganj																					
SL. No.	Block	Panchayat	Village	Ward No.	Location of Source	Parameters													Date of Testing	Remarks	
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)			Total Coli
1	Kuchaykote	Sisawa	Paharpur	4	J.K INTERNATIONAL SCHOOL	7.72	0.2	587	381	228	54	25	15	262	0.18	0.16	18.2	0.2	Absent	26/05/2025	
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**		

  
26.05.2025  
Lab Assistant / Chemist  
DLL, P.H. Division, Gopalganj

  
Per   
P.H.Division, Gopalganj

  
26/05/25  
Executive Engineer  
P.H.Division, Gopalganj

  
**MANAGER**  
J.K. International School  
N.H.-28, Paharpur, Kuchaikote, Gopalganj

  
**Principal**  
J.K. International School  
Paharpur, Kuchaikote, Gopalganj